



WASILLA 2016 CCR

PSWID AK2224646

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to ensure the water quality and system operations are communicated to you the customer.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Wasilla Public Water System is comprised of several ground water wells. Deep aquifers from four active locations ranging from 150 feet to 250 feet below the ground's surface supply all of the water demands. Active well locations; WL001 lat. 61.598618 lon. -149.447800, WL002 lat. 61.599046 lon. -149.447265, WL004 lat. 61.590514 lon. -149.499977, WL005 lat. 61.590857 lon. -149.496406. Water is delivered through four atmospheric storage tanks providing fire protection and two booster stations maintaining pressure throughout the distribution system. We also maintain another four ground water sources that can supply additional water if needed. Located at, lat. WL003 lat. 61.584060 lon. -149.453045, WL006 lat. 61.592002 lon. -149.520145, WL007 lat. 61.552887 lon. -149.326567, WL008 lat. 61.551293 lon. -149.314341, WL009 lat. 61.577171 lon. -149.421460

Source water assessment and its availability

Source water is untreated water from streams, rivers, lakes, or underground aquifers that is used to supply public drinking water. Preventing drinking water contamination at the source makes good public health sense, good economic sense, and good environmental sense. You should be aware of the challenges in keeping drinking water safe and take an active role in protecting it. There are many ways that you can get involved in drinking water protection activities to prevent the contamination of our water sources; such as dispose properly of household chemicals, help clean up the watershed that is the source of our community's water, and attend public meetings to ensure that the community's need for safe drinking water is considered in making decisions about land use.

Source Water Assessment (SWA) Reports have been completed by the ADEC Drinking Water Protection Program as a first step towards voluntary local source water protection efforts.

Vulnerability rankings are assigned based on the susceptibility of the drinking water source to potential contamination, recent sampling results and the presence of potential contaminant sources. They do not necessarily indicate these contaminants will reach our source of water. Our water system has received the following vulnerability rankings: The public water system for the Wasilla System is a Class A water system consisting of 4 source intakes. The water system is located in Wasilla and the intake for this PWSID is a groundwater wells. The wellheads received a susceptibility of "low" and the aquifer received a susceptibility rating of "low". Combining these scores produces a natural susceptibility of "low" for the source. In addition, this water system has received a vulnerability rating of "medium" for bacteria/viruses, "medium" for nitrates/nitrites, "low" for volatile organic chemicals, "medium" for heavy metals, "low" for other organic chemicals, and "low" for synthetic organic chemicals.

Completed source water assessments are available at ADEC's Drinking Water Protection Program website: http://www.dec.state.ak.us/eh/dw/DWP/source_water.html, by calling 907.269.7521, or at 555 Cordova St, Anchorage, AK; or at the Alaska Resources Library and Information Services, 3150 C St, Anchorage, AK.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and

volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

The Wasilla City Council meets on the second and fourth Mondays of each month at 7:00 p.m. in the Council Chambers located at City Hall, at 290 E. Herning Ave. All residents are encouraged to participate in these meetings. Agendas and minutes for the meeting are available on line at the City of Wasilla web site: <http://www.cityofwasilla.com>

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectants to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.

Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.

Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.

Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.

Water plants only when necessary.

Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait.

If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.

Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.

Teach your kids about water conservation to ensure future generations use water wisely. Make it a family effort to reduce next month's water bill!

Visit www.epa.gov/watersense for more information.

Cross Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations and insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below, please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

Boiler/ Radiant heater (water heaters not included)

Underground lawn sprinkler system

Pool or hot tub (whirlpool tubs not included)

Additional source(s) of water on the property

Decorative pond

Watering trough

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.

Pick up after your pets.

If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.

Dispose of chemicals properly; take used motor oil to a recycling center.

Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.

Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CITY OF WASILLA PWSID AK2224646 is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps

you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Additional Information for Arsenic

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chloramine (as Cl ₂) (mg/L)	4	4	.8	.1	.8	2016	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	11	1	11	2016	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes]	NA	80	15	3	15	2016	No	By-product of drinking water disinfection

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source	
				Low	High				
(ppb)									
Inorganic Contaminants									
Arsenic (ppb)	0	10	7.1	NA	7.1	2015	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes	
Barium (ppm)	2	2	.0212	NA	.0212	2013	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	
Chromium (ppb)	100	100	.663	NA	.663	2013	No	Discharge from steel and pulp mills; Erosion of natural deposits	
Cyanide (ppb)	200	200	5	NA	5	2013	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories	
Fluoride (ppm)	4	4	.113	NA	.113	2013	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories	
Nitrate [measured as Nitrogen] (ppm)	10	10	1.25	NA	1.25	2016	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	
Radioactive Contaminants									
Alpha emitters (pCi/L)	0	15	.22	-	.071	.22	2016	No	Erosion of natural deposits
Radium (combined 226/228) (pCi/L)	0	5	.38	.023	.38	2016	No	Erosion of natural deposits	
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source		
Inorganic Contaminants									
Copper - action level at consumer taps (ppm)	1.3	1.3	.38	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits		
Inorganic Contaminants									
Lead - action level at consumer taps (ppb)	0	15	2.9	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits		

Additional Contaminants

In an effort to insure the safest water possible the State has required us to monitor some contaminants not required by Federal regulations. Of those contaminants only the ones listed below were found in your water.

Contaminants	State MCL	Your Water	Violation	Explanation and Comment
NICKEL		3.44 UG/L	No	

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
mg/L	mg/L: Number of milligrams of substance in one liter of water
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: JOHN BECKER
 Address: 290 E HERNING AVENUE
 WASILLA, AK 99654
 Phone: (907) 373-9010
 E-Mail: jbecker@ci.wasilla.ak.us

