

Non-Code Ordinance

By: Public Works Department
Introduced: January 10, 2022
Public Hearing: January 24, 2022
Adopted: January 24, 2022

Yes: Brown, Graham, Harvey, Johnson, Sullivan-Leonard, Velock
No: None
Absent: None

**City of Wasilla
Ordinance Serial No. 22-05**

An Ordinance Of The Wasilla City Council Amending The Fiscal Year 2022 Budget By Appropriating \$100,000 From The Water Fund, Fund Balance For The Spruce Alternative Well.

Section 1. Classification. This is a non-code ordinance.

Section 2. Purpose. To appropriate funding from the water fund balance for the Spruce Alternative Well.

Section 3. Appropriation of Funds. The funds are appropriated to the following:

Spruce Ave Water Tank Repairs	320-4369-436.45-63	\$100,000
-------------------------------	--------------------	-----------

Section 4. Source of Funds.

Fund Balance	320-0000-253.20-00	\$100,000
--------------	--------------------	-----------


Section 5. Effective Date. This ordinance shall take effect upon adoption.

ADOPTED by the Wasilla City Council on January 24, 2022.



Glenda D. Ledford, Mayor

ATTEST:



Jamie Newman, MMC, City Clerk

[SEAL]

City of Wasilla
Legislative Staff Report
Ordinance Serial No. 22-05
(Non-Code Ordinance)

An Ordinance Of The Wasilla City Council Amending The Fiscal Year 2022 Budget By Appropriating \$100,000 From The Water Fund, Fund Balance For The Spruce Alternative Well.

Originator: Robert L Walden, PE; Acting Director of Public Works
Date: 12/30/2021

Agenda of: 1/10/2022

Route to:	Department Head	Signature	Date
X	Finance Director		1-5-22
X	Deputy Administrator		1-5-22
X	City Clerk		1/5/2021
X	Mayor		1/5/22

Fiscal Impact: yes or no

Funds Available: yes or no

Account name/number:

Spruce Ave Water Tank Repairs	320-4369-436.45-63	\$ 100,000
Fund Balance	320-0000-253.20-00	\$ 100,000
		Total: \$100,000

Attachments: Ordinance Serial No. 22-05 (2 pages)

Summary Statement:

The old 6-inch back up well is outdated for our current needs. During the main well shutdown this last summer the continued use burned up the old pump in the current back-up well. HDL design engineers are recommending a new 8-inch casing with a new 6-inch pump that will provide three times as much GPM for our growing demand. This will create an improved system redundancy, better water quality from our best aquifer, and reduce labor costs having to currently turn on three different well locations then monitor them since those controls are not as intelligent as the Spruce controls. Money is coming from the water fund healthy positive balance.

Proposed Action: Introduce and set the Ordinance for public hearing.