

COMMERCIAL BUILDINGS
RESTAURANTS

M.E.A. METER BASE
AND BREAKER BOX

CITY BREAKER BOX
PUMP CONTROL / ALARM PANEL

ALARM / POWER CONDUITS
MUST BE RIGID AT
ALL POINTS

SEPTIC TANK
(2 COMPARTMENT)

PUMP VAULT
FIGURE 430

RIGID CONDUIT

CLEANOUT

KITCHEN WASTE
INTERSEPTER TANK

CLEANOUTS

GRAVITY SERVICE LINE

CLEANOUT

LOW PRESSURE DISCHARGE
SERVICE LINE WITH HEAT TRACE
AND INSULATION SHALL BE
INSTALLED PERPENDICULAR TO
THE SEWER MAIN WHENEVER
POSSIBLE. THE SEWER SERVICE
LINE SHALL BE INSTALLED WITH
A MINIMUM AMOUNT OF
HORIZONTAL CURVATURE.

PRIVATE PROPERTY

PROPERTY LINE

PUBLIC RIGHT-OF-WAY

PRESSURE
SEWER MAIN

FLOW

VARIES

5' MIN.

10' MIN.

MIN. 5' MAX 10'

DATE:
1/23/12
DRAWN BY:
Utility Maint.
CHECKED BY:
D P W

CITY OF
WASILLA

PLAN VIEW
SERVICE CONNECTION
(COMMERCIAL)

SCALE: NONE
SHEET 1 OF 1
FIGURE: 422 A